

# CERTIFICATE OF CALIBRATION



## eGauge Systems LLC

1644 Conestoga St, Suite 2  
 Boulder, CO 80301, USA  
 Tel: +1 (720) 545-9767 Fax: +1 (720) 545-9768  
<http://www.egauge.net/>

Test Result: **0.5% PASS**  
 Certificate No.: **EXAMPLE**  
 Issue Date: July 9, 2019  
 Page: 1 of 1

Device Serial No.: **EXAMPLE**  
 Measurement Date: July 2, 2019  
 Calibration Date: July 2, 2019  
 Model Type Number: EG4130  
 Description: Multi-channel power meter, data-logger, and web-server.  
 Sensors Used: C1-15, B1-15: Continental Control ACT-0750-100 (100A/0.75")  
 Standard Used: Radian RD-20-103, S/N 207036, v07.22.04  
 Ambient Temperature/Humidity: 24.8 °C / 39%  
 Applied Voltage: 118.7 Vrms / 59.0 Hz

### Power Factor 1 (current in phase with voltage)

Applied			Measured Error [%] <sup>3</sup>														
Current	Energy	Tol.	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10	#11	#12	#13	#14	#15
15.0 A	30.0 Wh	±0.2% <sup>1</sup>	+0.04	+0.03	+0.03	+0.03	+0.03	+0.02	+0.03	+0.02	+0.02	+0.04	+0.03	+0.02	+0.04	+0.03	<b>+0.07</b>
1.5 A	3.0 Wh	±0.5% <sup>2</sup>	+0.04	+0.06	+0.06	+0.01	+0.07	-0.02	+0.08	-0.02	+0.04	+0.08	+0.07	+0.02	+0.03	+0.06	+0.06
50.1 A	50.5 Wh	±0.5% <sup>2</sup>	+0.01	+0.01	+0.01	+0.01	+0.00	+0.01	+0.01	+0.01	+0.01	+0.01	+0.01	+0.01	+0.01	<b>+0.02</b>	<b>+0.02</b>
94.2 A	95.1 Wh	±0.5% <sup>2</sup>	+0.01	+0.00	+0.00	+0.00	+0.00	+0.01	+0.01	+0.01	+0.01	+0.00	+0.00	+0.01	+0.01	+0.01	+0.01
Current	Energy	Tol.	#16	#17	#18	#19	#20	#21	#22	#23	#24	#25	#26	#27	#28	#29	#30
15.0 A	30.0 Wh	±0.2% <sup>1</sup>	+0.02	+0.01	+0.02	+0.02	+0.01	+0.01	+0.03	+0.01	+0.03	+0.04	+0.02	+0.02	+0.03	+0.03	+0.04
1.5 A	3.0 Wh	±0.5% <sup>2</sup>	<b>+0.14</b>	+0.08	+0.04	+0.05	+0.06	+0.09	+0.11	+0.12	+0.09	+0.10	+0.09	+0.07	+0.08	+0.04	+0.11
50.1 A	50.5 Wh	±0.5% <sup>2</sup>	+0.01	<b>+0.02</b>	+0.01	+0.01	+0.01	<b>+0.02</b>	+0.01	+0.01	+0.00	+0.01	+0.00	+0.00	+0.01	+0.00	-0.00
94.2 A	95.1 Wh	±0.5% <sup>2</sup>	+0.01	+0.01	+0.01	+0.01	+0.01	<b>+0.02</b>	+0.01	+0.01	+0.01	-0.00	+0.00	+0.00	+0.01	-0.00	+0.00

### Power Factor 0.5 leading (current leading voltage by 60°)

Current	Energy	Tol.	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10	#11	#12	#13	#14	#15
15.0 A	7.1 Wh	±0.6% <sup>2</sup>	+0.08	+0.13	+0.19	+0.13	+0.18	+0.09	+0.12	+0.08	+0.18	+0.05	+0.21	+0.19	+0.15	+0.22	+0.15
1.5 A	1.4 Wh	±1.0% <sup>2</sup>	+0.17	+0.30	+0.27	+0.24	+0.17	+0.35	+0.18	+0.32	<b>+0.42</b>	+0.10	+0.09	+0.31	+0.31	+0.30	+0.20
49.7 A	23.5 Wh	±0.6% <sup>2</sup>	+0.09	+0.15	+0.19	+0.12	+0.20	+0.12	+0.10	+0.10	+0.18	+0.05	+0.19	+0.18	+0.13	+0.22	+0.15
93.8 A	44.2 Wh	±0.6% <sup>2</sup>	+0.14	+0.22	+0.26	+0.19	+0.26	+0.16	+0.17	+0.16	+0.24	+0.03	+0.25	+0.24	+0.17	+0.28	+0.20
Current	Energy	Tol.	#16	#17	#18	#19	#20	#21	#22	#23	#24	#25	#26	#27	#28	#29	#30
15.0 A	7.1 Wh	±0.6% <sup>2</sup>	+0.12	+0.12	<b>+0.25</b>	+0.05	+0.04	+0.06	+0.00	+0.20	-0.05	-0.20	-0.15	+0.03	+0.01	+0.15	+0.14
1.5 A	1.4 Wh	±1.0% <sup>2</sup>	+0.18	+0.30	+0.41	+0.17	+0.24	+0.08	+0.24	+0.31	+0.09	-0.08	-0.02	+0.19	+0.02	+0.34	+0.27
49.7 A	23.5 Wh	±0.6% <sup>2</sup>	+0.10	+0.11	<b>+0.23</b>	+0.04	+0.01	+0.05	+0.00	+0.19	-0.05	-0.22	-0.14	+0.02	+0.03	+0.14	+0.14
93.8 A	44.2 Wh	±0.6% <sup>2</sup>	+0.17	+0.18	<b>+0.30</b>	+0.11	+0.07	+0.12	+0.07	+0.24	+0.01	-0.15	-0.09	+0.06	+0.10	+0.20	+0.19

### Power Factor 0.5 lagging (current lagging voltage by 60°)

Current	Energy	Tol.	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10	#11	#12	#13	#14	#15
15.0 A	7.9 Wh	±0.6% <sup>2</sup>	-0.08	-0.13	-0.14	-0.12	-0.17	-0.06	-0.07	-0.08	-0.15	-0.04	-0.16	-0.16	-0.09	-0.17	-0.13
1.5 A	1.6 Wh	±1.0% <sup>2</sup>	-0.35	-0.33	<b>-0.37</b>	-0.20	-0.36	-0.05	-0.26	-0.21	-0.24	-0.15	<b>-0.37</b>	-0.23	-0.21	-0.22	-0.17
49.8 A	26.4 Wh	±0.6% <sup>2</sup>	-0.07	-0.14	-0.16	-0.11	-0.17	-0.08	-0.09	-0.09	-0.15	-0.04	-0.18	-0.16	-0.10	<b>-0.19</b>	-0.13
94.2 A	49.5 Wh	±0.6% <sup>2</sup>	-0.12	-0.19	-0.22	-0.16	-0.23	-0.14	-0.15	-0.13	-0.21	-0.01	-0.21	-0.22	-0.15	-0.25	-0.17
Current	Energy	Tol.	#16	#17	#18	#19	#20	#21	#22	#23	#24	#25	#26	#27	#28	#29	#30
15.0 A	7.9 Wh	±0.6% <sup>2</sup>	-0.09	-0.09	<b>-0.22</b>	-0.05	-0.01	-0.04	-0.00	-0.15	+0.05	+0.19	+0.13	+0.01	+0.01	-0.11	-0.12
1.5 A	1.6 Wh	±1.0% <sup>2</sup>	-0.18	-0.22	-0.16	-0.14	-0.03	-0.17	+0.04	-0.22	-0.07	+0.09	+0.01	+0.14	-0.08	-0.22	-0.31
49.8 A	26.4 Wh	±0.6% <sup>2</sup>	-0.08	-0.10	<b>-0.19</b>	-0.04	+0.00	-0.03	+0.01	-0.16	+0.05	+0.17	+0.13	-0.00	-0.03	-0.12	-0.11
94.2 A	49.5 Wh	±0.6% <sup>2</sup>	-0.15	-0.15	<b>-0.26</b>	-0.09	-0.05	-0.10	-0.05	-0.21	-0.01	+0.14	+0.08	-0.05	-0.08	-0.17	-0.16

#### Footnotes:

- 1: Absolute tolerance. This test establishes the reference condition.
- 2: Tolerance relative to reference condition.
- 3: Maximum deviation(s) shown in bold.